

## AGRO EMC cable glands Progress® nickel-plated brass with contact sleeve and

**Short entry thread Pg****Type approval: Progress MS EMC KB EX**

- One-piece sealing insert
- not overall length insulated

|                       |                                                   |
|-----------------------|---------------------------------------------------|
| <b>Article no:</b>    | <b>EX1803.80.16.140</b>                           |
| EAN:                  | 7611614177052                                     |
| Material              | Nickel-plated brass                               |
| Screws                | Stainless steel A2                                |
| Seal                  | TPE                                               |
| O-ring                | FPM                                               |
| Operation temperature | -60°C / +100°C                                    |
| Protection class      | IP 66 / IP 68 (up to 10 bar)                      |
| Test standard         | IEC EN 60079-0 / IEC EN 60079-7 / IEC EN 60079-31 |
| Gas                   | II 2G Ex eb IIC Gb                                |
| Dust                  | II 2D Ex tb IIIC Db                               |
| Zone                  | Gas 1 and 2 / dust 21 and 22                      |
| Certificate           | SEV 15 ATEX 0151                                  |
| IECEx Certificate     | IECEx SEV 15.0018                                 |
| CCC Certificate       | CCC 2022322313004717                              |
| Entry thread          | Pg 16                                             |
| Clamping range min.   | 11.0 mm                                           |
| Clamping range max.   | 14.0 mm                                           |
| Wrench size           | 24 mm                                             |
| Dimension H           | 31 mm                                             |
| Thread length L       | 6 mm                                              |
| Note                  | -                                                 |
| Dispatch              | 50                                                |

1 = Certificate SEV 15 ATEX 0152X / IECEx SEV 15.0019X\_x000D\_  
Long entry thread available on request